

TYPE EXAMINATION CERTIFICATE

No. 19-1180-01

Certificate issued by Notified Body N° 1611

1. Product name: Engineered Wood Flooring
2. Product material: Oak, Elm, Birch, Ash, Larch, Pinewood, Black walnut, Teak, Cherry, Jatoba, IPE, Cabreuva, Keruing, Merbau, Padouk, Maple and Iroko.
3. Product type:
 - a. thickness: 10 mm - 21 mm
 - b. density: 750±50 kg/m³
4. Numerical code of product classification:
 - a. fire behaviour: **D fl s1**
 - b. formaldehyde: **E1**
5. Usage of the product: indoor flooring
6. Applicant: DALIAN YINLONG WOOD CO., LTD.
7. Address: NO.10 BOHAI STREET, HUSHAN COMMUNITY, TIEXI SUBDISTRICT, PULANDIAN, DISTRICT, DALIAN, LIAONING CHINA
8. Manufacturer: MUDANJIANG JINSEN WOOD PRODUCTS CO.,LTD.
9. Address: NO.108 TONGXIANG ROAD AIMIN DISTRICT MUDANJIANG CITL CHINA

This certificate assures the compliance of properties of the product, which complies with the technical requirements referenced in EN 14342, EN 13501-1 and EN 717-1. The certificate only applies to materials that correspond to the tested sample.


The results of tests and findings on conformity of the properties of the given type with technical requirements are referenced in classification report CR-19-1180-01, Test Reports 19-1180-01, 19-1180-02 and MVZ-A-2019-001208.

Date of issuing: 9/12/2019

Valid until: December 2024

The Centre for Textile Science and Engineering of Ghent University (Belgium) is recognized as notified laboratory N° 1611 for the European regulation, 305/2011 for construction products.

Johanna Louwagie
Head Certification



Prof. Dr. Paul KIEKENS, dr. h. c.
Director